



NOTE:

- 1. For outdoor unit installation , allow at least 2 sides of space around the unit ensure ventilation flue.
- $2. \\ The connecting pipe , should all the insulated with insulation pipe.$
- 3.Piping length is within 20m.
- 4. Height different of the piping between the indoor unit and outdoor unit should be within 10m.