

HITACHI



CE DECLARATION OF CONFORMITY

We Johnson Controls-Hitachi Air Conditioning Wuhu Co., Ltd.
No.2, Qiluoshan Road. Wuhu District, China (Anhui) Pilot Free Trade Zone
The People's Republic of China

As the manufacturer, declare under our sole responsibility that the products:-

Type Wall Mounted Single Split type Room Air Conditioner

Brand **HITACHI**

| Models | Indoor unit | Outdoor unit |
|--------|--------------|--------------|
| | RAK-DJ18PHAE | RAC-DJ18PHAE |
| | RAK-DJ25PHAE | RAC-DJ25PHAE |
| | RAK-DJ35PHAE | RAC-DJ35PHAE |
| | RAK-DJ50PHAE | RAC-DJ50PHAE |

Serial No. See the number on the unit rating label

Comply with the following Directives of the Council of the European Community

- Council Directive 2014/35/EU, relating to electrical equipment designed for use within certain voltage limits (LVD).
- Council Directive 2014/30/EU, relating to electromagnetic compatibility (EMC).
- Council Directive 2009/125/EC, regard to establishing a framework for the setting of ecodesign requirement for energy-related products.
- Commission Regulation (EU) No.206/2012, implementing Directive 2009/125/EC in regard to ecodesign requirement for air conditioners and comfort fans.
- Regulation (EU) 2017/1369 of the European Parliament and of the Council of 4 July 2017 setting a framework for energy labelling and repealing Directive 2010/30/EU.
- Commission Delegated Regulation (EU) No.626/2011, supplementing regulation (EU) 2017/1369 in regard to energy labeling of air conditioners
- Council Directive 2011/65/EU on the restriction of the use of the certain hazardous substances in electrical and electronic equipment
- Council Directive 2014/68/EU, relating to pressure equipment.
See attached Declaration of Conformity under Council Directive 2014/68/EU, relating to pressure equipment.

and are in conformity with the following International Standards

LVD : EN 60335-2-40:2003 + A11:2004 + A12:2005 + A1:2006 + A2:2009 + A13:2012
EN 60335-1:2012 + A11:2014+A13:2017+A1:2019+A14:2019+A2:2019+A15:2021
EN 62233:2008

EMC : EN 55014-1: 2017+A11 :2020
EN 55014-2 :2015
EN IEC 61000-3-2 :2019
EN 61000-3-3 :2013+A1 :2019

RED : EN 301 489 -1 V2.2.3
EN 301 489-17 V3.2.4
EN 300 328 V2.2.2
EN IEC 62311 :2020

ENERGY EFFICIENCY : EN14511-3 :2018, EN 14825 :2016
SOUND POWER LEVEL : EN 12102 -1:2017
RoHS: EN 50581:2012

Johnson Controls-Hitachi Air Conditioning Wuhu Co., Ltd.

2022-01-25
(Place/Date)

Xianping.Wu.
Xianping.Wu

JCH-WH GED Engineering Department Manager

(Company stamp)

Johnson Controls-Hitachi Air Conditioning Wuhu Co., Ltd.
Tel: +86-553-5844215



Attachement to EU Declaration of Conformity
according to Annex IV of Directive 2014/68/EU – Pressure equipment

We: Johnson Controls-Hitachi Air Conditioning Wuhu Co., Ltd.
No.2, Qiluoshan Road. Wuhu District, China (Anhui) Pilot Free Trade
Zone
The People's Republic of China

declare under our sole responsibility that the machines

Pressure Equipment,

Models,

| | |
|--------------|--------------|
| indoor | outdoor |
| RAK-DJ18PHAE | RAC-DJ18PHAE |
| RAK-DJ25PHAE | RAC-DJ25PHAE |
| RAK-DJ35PHAE | RAC-DJ35PHAE |
| RAK-DJ50PHAE | RAC-DJ50PHAE |

Manufacturer, : Johnson Controls-Hitachi Air Conditioning Wuhu Co., Ltd.
No.2, Qiluoshan Road. Wuhu District, China (Anhui) Pilot Free Trade Zone
The People's Republic of China

Serial No, See the number on the unit label.

Characteristics,

| Pressure Equipment Components | Category under 2014/68/EU | Assessment Procedure |
|---------------------------------|---------------------------|----------------------|
| Heat Exchanger | SEP | --- |
| Compressor (main chamber) | Category II | Module A2 |
| Compressor (liquid tank) | SEP | --- |
| Piping and pressure accessories | SEP | --- |

Equipment's category,

II

Conformity Assessment Procedure for the equipment: **A2**


Notified Body,

TÜV Rheiland Industrie Service GmbH, Am Grauen Stein,
D-51105 Köln / Cologne, Germany
ID No. 0035
Certificate No. 01 202 CHN/Ü-200003

comply with Council Directive 2014/68/EU, relating to pressure equipment.

Name,: Andy zhang
Position,: General Manager

JOHNSON CONTROLS-HITACHI AIR
CONDITIONING WUHU CO., LTD.



Wuhu, PR. Of China, 25-1-2022